




Buildings and Sustainability: Roles of Codes

**Harvey Bryan, Ph.D., FAIA, LEED AP
School of Architecture & Landscape Architecture
School of Sustainability
Arizona State University**



Commercial Codes and Standards





ASHRAE 90-1975

Being the first attempt at an Energy Standard – It got a number of important things wrong, especially as far as commercial buildings were concerned.

- Residential and Commercial in one standard -- wrong
- Envelope was a function of degree-days -- wrong
- Restricted glazing area (10-15%) -- wrong
- Reduced ventilation which later created IAQ problems and pushed buildings to All Air/VAV systems
- Was very prescriptive in nature and not very flexible



Building Energy Performance Standard 1978-82

Was the first attempt at an energy performance standard for buildings, it was far ahead of its time. The AIA Research Corporation did much of the research in developing the BEPS Standard. However, it failed because of the:

- Lack of government commitment, lost funding
- Site vs. source energy issues were never resolved
- Complexity of performance simulation (DOE 2 required at that time a mainframe computer for analysis)




Building Energy Performance Standard (BEPS) - 1980

State	SMSA	Clinc	Community Center	Gymnasium	Hospital	Hotel/Motel	Multifamily High Rise	Multifamily Low Rise	Nursing Home	Large Office	Small Office	Elementary School	Secondary School	Shopping Center	Retail	Theater/ Auditorium	Warehouse
Minnesota	Minneapolis	142	109	144	335	180	140	110	175	123	117	122	138	198	155	157	93
Missouri	St. Louis	133	110	136	353	175	128	112	163	119	109	105	128	192	150	149	72
Washington DC	D.C.	127	107	129	353	169	120	109	164	115	104	96	121	185	144	142	63
Florida	Miami	152	142	161	406	203	133	147	201	140	125	103	141	219	179	178	41
Texas	Dallas	131	116	136	358	175	119	119	171	120	107	94	124	190	152	150	50
California	San Diego	114	103	117	364	158	104	106	153	107	92	75	107	172	134	128	40
Oregon	Portland	119	98	120	353	161	116	99	154	108	97	91	115	176	135	131	66
Massachusetts	Boston	125	101	126	338	165	121	102	159	111	102	99	121	181	140	139	72

Units: Source Energy in kBtu/ft²-yr



DOE/OBT Budget -- \$ Millions, constant 1982






ASHRAE 90.1-1989

Attempted to introduce a performance track into a prescriptive standard

- Corrected many of the problems with 90-75
- Divided the standard into commercial (90.1) and residential buildings (90.2)
- Envelope was a function of internal loads
- Was more flexible & less prescriptive than 90-75
- Complexity was overcome with computer tools (for envelope and lighting) and a whole building energy modeling approach (ECB) was added



ASHRAE 90.1-1989





ASHRAE 90.1-1999

Built on the ASHRAE 90.1-1989 Standard, attempted to better integrate the performance track into the standard

- Made the building envelope more stringent
- Made HVAC equipment efficiency more stringent
- Made improvements to the whole building energy modeling approach (ECB)



ASHRAE 90.1-2004

Built on the ASHRAE 90.1-1999 Standard, created an approximate 10% improvement over previous version

- Significant improvement in lighting efficiency
- Made the building envelope more stringent
- Made HVAC equipment efficiency more stringent
- Made improvements to the whole building energy modeling approach (ECB) and introduced an informative performance based modeling approach (Appendix G)



ASHRAE Appendix G

TABLE G3.1 (Continued) Modeling Requirements for Calculating Proposed and Baseline Building Performance

No.	Proposed Building Performance	Baseline Building Performance
4.	<p>Schedules</p> <p>Schedules capable of modeling hourly variations in occupancy, lighting power, miscellaneous equipment power, thermostat set-points, and HVAC system operation shall be used. The schedules shall be typical of the proposed building type as determined by the designer and approved by the rating authority.</p> <p>HVAC Fan Schedules. Schedules for HVAC fans shall run continuously whenever spaces are occupied and shall be cycled on and off to meet heating and cooling loads during unoccupied hours.</p> <p>Exceptions: Where no heating and/or cooling system is to be modeled and a heating or cooling system is being modeled only to meet the requirements described in this table, heating and/or cooling system fans shall not be simulated as running continuously during occupied hours but shall be cycled on and off to meet heating and cooling loads during all hours.</p>	<p>Same as Proposed Design.</p> <p>Exception: Schedules may be allowed to differ between proposed design and baseline building design when necessary to model nonstandard efficiency measures, provided that the revised schedules have the approval of the rating authority. Measures that may warrant use of different schedules include, but are not limited to, lighting controls, natural ventilation, demand control ventilation, and measures that reduce service water heating loads.</p>
5.	<p>Building Envelope</p> <p>All components of the building envelope in the proposed design shall be modeled as shown on architectural drawings or as built for existing building envelopes.</p> <p>Exceptions: The following building elements are permitted to differ from architectural drawings:</p> <p>(a) All unenclosed assemblies (e.g., projecting balconies, perimeter edges of intermediate floor slabs, concrete floor beams over parking garages) shall be separately modeled. Any other envelope assembly that covers less than 5% of the total area of that assembly type (e.g., exterior walls) need not be separately described provided that it is similar to an assembly being modeled. If not separately described, the area of an envelope assembly shall be added to the area of an assembly of that same type with the same orientation and thermal properties.</p> <p>(b) Exterior surfaces whose azimuth orientation and tilt differ by less than 45 degrees and are otherwise the same may be described as either a single surface or by using multipliers.</p> <p>(c) For exterior roofs, the roof surface may be modeled with a reflectance of 0.65 if the reflectance of the proposed design roof is greater than 0.70 and its emittance is greater than 0.75. Reflectance values shall be based on testing in accordance with ASTM E909, ASTM E1175, or ASTM E1918, and the emittance values shall be based on testing in accordance with ASTM C835, ASTM C1371, or ASTM E408. All other roof surfaces shall be modeled with a reflectance of 0.26.</p> <p>(d) Manual fenestration shading devices such as blinds or shades shall not be modeled. Automatically controlled fenestration shades or blinds may be modeled. Permanent shading devices such as fins, overhangs, and light shelves may be modeled.</p>	<p>Equivalent dimensions shall be assumed for each exterior envelope component type as in the proposed design, i.e., the total gross area of exterior walls shall be the same in the proposed and baseline building design. The same shall be true for the areas of roofs, floors, and doors, and the exposed perimeter of concrete slabs on grade shall also be the same in the proposed and baseline building design. The following additional requirements shall apply to the modeling of the baseline building design:</p> <p>(a) Orientation. The baseline building performance shall be generated by simulating the building with its actual orientation and again after rotating the entire building 90, 180, 270 degrees, then averaging the results. The building shall be modeled as their it does not shade itself.</p> <p>(b) Opaque assemblies. Opaque assemblies used for new buildings or additions shall conform with the following common, lightweight assembly types and shall match the appropriate assembly maximum U-factor in Tables 5.5-1 through 5.5-8:</p> <ul style="list-style-type: none"> • Roofs – Insulation exteriorly above deck • Above-grade walls – Steel-framed • Floors – Steel-joist <p>Opaque door types shall match the proposed design and conform to the U-factor requirements from the same tables.</p> <ul style="list-style-type: none"> • Slab-on-grade floors shall match the R-factor for unheated slabs from the same tables. <p>Opaque assemblies used for alterations shall conform with 5.1.3.</p> <p>(c) Vertical Fenestration. Vertical fenestration area for new buildings and additions shall equal that in the proposed design or 40% of gross above-grade wall area, whichever is smaller, and shall be distributed uniformly in horizontal bands across the four orientations. Fenestration U-factor shall match the appropriate requirements in Tables 5.5-1 through 5.5-8 for the applicable vertical glazing percentage for U_{glaz}. Fenestration solar heat gain coefficient (SHGC) shall match the appropriate requirements in Tables 5.5-1 through 5.5-8 using the value for SHGC_{glaz} for the applicable vertical glazing percentage. All vertical glazing shall be modeled as fixed and shall be assumed to be finish with the exterior wall, and no shading projections shall be modeled. Manual window shading devices such as blinds or shades shall not be modeled. The fenestration area for envelope alterations shall reflect the limitations on area, U-factor, and SHGC as described in 5.1.3.</p> <p>(d) Skylight and Clerestory Windows. Skylight area shall be equal to that in the proposed building design or 5% of the gross roof area that is part of the building envelope, whichever is smaller. If the skylight area of the proposed building design is greater than 5% of the gross roof area, baseline skylight area shall be decreased by an identical percentage in all roof components in which skylights are located to reach the 5% skylight-to-roof ratio. Skylight orientation and tilt shall be the same as in the proposed building design. Skylight U-factor and SHGC properties shall match the appropriate requirements in Tables 5.5-1 through 5.5-8.</p> <p>(e) Roof Sheds. All roof surfaces shall be modeled with a reflectivity of 0.30.</p> <p>(f) Existing Buildings. For existing building envelopes, the baseline building design shall reflect existing conditions prior to any revisions that are part of the scope of work being evaluated.</p>



ASHRAE 90.1-2007

Built on the ASHRAE 90.1-1999 Standard, created an approximate 15% improvement over that version

- Made the building envelope more stringent
- Made HVAC equipment efficiency more stringent
- Made improvements to the whole building energy modeling approach (ECB) and the informative performance based modeling approach (Appendix G)




We have had 30 years of Energy Standards

We have to ask the question:
How well have these standards performed?

DOE/EIA has a database called the Commercial Building Energy Consumption Survey (CBECS) which we can use to measure this.




Commercial Building Energy Consumption for the last 30 years



Source: after James E. Woods, Ph.D., P.E.




EISA/EO 13423, For All Federal Facilities



(source: GSA 2007)




How low can we go?



The Building Sector's CO₂ Mitigating Potential for 2030

GtCO₂-eq/yr



WMO

INTERGOVERNMENTAL PANEL ON CLIMATE CHANGE (IPCC)



UNEP




Setting Benchmarks - Architecture 2030

Year	Percentage Reduction
Today	50
2010	60
2015	70
2020	80
2025	90
2030	100 (Carbon Neutral)



Where do we need to get over the next 22 years



Source: after James E. Woods, Ph.D., P.E.



What we can learn from this experience

The ASHRAE approach has not worked particularly well.

A purer performance approach would have worked better.

We now have a building performance database that we can use as a benchmarking tool.

Global warming concerns (in a carbon cap & trade based system) will be driving the next generations of codes, will be using CO₂ and not energy as the metric.

It will be a challenge to get to zero net energy or carbon neutral buildings by 2030.

Any approach will have to measure the entire environmental impact of a building, i.e., be sustainable.



LEED® for New Construction 2009

For 1st Public Comment



LEED 2009

- Structure will be very similar to the present LEED NC 2.2.
- Will be more stringent than LEED NC 2.2.
- Is a recognized brand and has considerable support.
- Now has 100 rather than 69 points.
- Now has regional bonus points.
- Uses energy and not CO₂ as a metric.
- Slow uptake only has 1800 certified buildings in 8 years.
- Not a true consensus document, not an ANSI approved document and it can't be codified.
- LEED buildings are not truly third party certified (does not meet ISO criteria) and does not have on-site verification.
- Completed USGBC review and will be published winter 2008 and go into operation January 2009.



BSR/ASHRAE/USGBC/IESNA Standard 189P

Public Review Draft

ASHRAE® Standard

Proposed Standard 189, *Standard for the Design of High-Performance Green Buildings Except Low-Rise Residential Buildings*

First Public Review (May 2007)
(Complete Draft for Full Review)

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed addendum, use the comment forms and instructions provided with this draft. The draft is subject to modification until it is approved for publication by the ASHRAE Board of Directors and ANSI. Until this time, the current edition of the standard remains in effect. The current edition of any standard may be purchased from the ASHRAE Bookstore @ <http://www.ashrae.org> or by calling 404-896-8400 or 1-800-827-4723 (for orders in the U.S. or Canada).

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© May 1, 2007. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-896-8400, Ext. 1126. Fax: 404-521-5478. E-mail: standards.section@ashrae.org.

AMERICAN SOCIETY OF HEATING, REFRIGERATING
AND AIR-CONDITIONING ENGINEERS, INC.
1791 Tullie Circle, NE Atlanta GA 30329-2355



ASHRAE Standard 189P

- 189 is a minimum Green Building Standard and not a rating system (can be used by both LEED and Green Globes).
- The International Code Council plans to codify it.
- Will use existing Building Inspectors for Certification.
- Uses CO₂ as one of its performance metrics.
- Dual prescriptive/performance paths reduces the need for extensive calculations.
- Sets a high level of performance – 30% better than ASHRAE 90.1-2007 (~50% better than 90.1-1999).
- Present level of environmental performance equals LEED high silver (under LEED NC 2.2.)
- Completed second public review and will need to go out for a third public review, publication fall/winter 2009.



GBI Proposed American National Standard 01-2008P: *Green Building Assessment Protocol for Commercial Buildings*

FIRST PUBLIC REVIEW DRAFT

This Standard - GBI Proposed American National Standard 01-2008P—provides a method of assessing commercial building projects in relation to commonly valued environmental and efficiency outcomes. This Standard is an assessment tool and does not purport to instruct users on the appropriate design, standards, applicable laws, codes or regulations for their building project(s). The use of the Standard does not establish, expressly or implicitly, the appropriate standard of care of licensed design or other professionals nor the appropriate duties and responsibilities of design, construction, or operations personnel.

The Green Building Initiative™ (GBI) does not guarantee or warrant the actual performance of any building project as a result of (1) the use of this Standard, or (2) a particular level of assessment obtained through the use of this Standard, whether through self-assessment or through the use of a third-party assessor. The Standard has been developed and structured to provide a general assessment tool for various attributes of building projects, as outlined in the Standard. The Standard is not a design tool or a quality or performance assurance system. Building project systems, technology, construction processes, design methodologies and best practices are constantly evolving and no building performance assessment system or tool, including this Standard, can account for these changes or the site-specific variances and limitations associated with individual building projects. The use of this Standard does not serve as a substitute for the work and advice of knowledgeable, licensed design and other professionals, skilled construction personnel, building operators, and dedicated building owners.

GBI makes no representations about the results to be obtained from using the Standard. GBI, to the fullest extent permitted by law, disclaims all warranties of any kind, whether express or implied, including, but not limited to, the implied warranties of merchantability, fitness for a particular purpose and non-infringement.

Information on the ANSI approved procedures used to develop this standard can be found at www.thegbi.org/commercial or by calling 1-877-GBI-GBI. To submit comments on this draft standard, please use the Comment Form and follow the instructions provided with the draft standard.





ANSI/GBI Green Building Rating Standard

- ANSI/GBI is a Green Building rating system, very similar to the Green Globes system (web based).
- The ANSI process will make it a Standard and could be codified by the International Code Council.
- Use third part verifiers, could use local Building Inspectors.
- Uses CO₂ as one of its performance metrics.
- Dual prescriptive/performance paths reduces the need for extensive calculations.
- Sets a high level of performance very closely to Architecture 2030.
- Present level of environmental performance surpasses LEED-NC 2.2 will probably be very close to LEED-2009.
- Presently out for second public review, expected publication fall 2009.



GAAS:538:08

For Immediate Release:
Thursday, July 17, 2008

Contact: Aaron McLearn
Rachel Cameron
916-445-4571

Gov. Schwarzenegger Issues Statement on Nation-Leading Green Building Code

Governor Arnold Schwarzenegger today issued the following statement on the California Building Standards Commission vote to adopt the nation's first statewide green building code:

“By adopting this first-in-the-nation statewide green building code, California is again leading the way to fight climate change and protect the environment. This is literally a groundbreaking move to ensure that when we break ground on all new buildings in the Golden State we are promoting green building and energy efficient new technologies. Cars and buildings are two of the leading users of energy – we’re already addressing cars, and these new building standards will ensure that California remains at the forefront of reducing our carbon footprint and conserving valuable natural resources while also protecting our economy. We have already committed to making our state-owned buildings more green and energy efficient and this statewide code will reduce greenhouse gas emissions, improve energy efficiency and conserve water in all new buildings.

“With today’s action, California continues to lead the nation and I commend the hard work of the Building Standards Commission to adopt the first-in-the-nation statewide green building standards.”

###



2007 CALIFORNIA GREEN BUILDING STANDARDS CODE

PREFACE

This document is Part 11 of the official compilation and publication of the adoptions, amendments and repeal of regulations to California Code of Regulations, Title 24, also referred to as the California Building Standards Code. This Part is known as the California Green Building Standards Code.

The California Legislature delegated authority to various State agencies, boards, commissions and departments to create building regulations to implement the state's statutes. These building regulations have the same force of law and take effect 100 days after their publication unless otherwise stipulated. The California Building Standards Code applies to all occupancies in the State of California as annotated.

A city, county or city and county may make necessary changes to the provisions contained in this code which are reasonably necessary because of local climatic, geological, or topographical conditions. Findings of the local condition(s) and the adopted local building standard(s) must be filed with the California Building Standards Commission to become effective and may not be effective sooner than the effective date of this edition of the California Building Standards Code. Building standards that were adopted by local ordinance and applicable to previous editions of the California Building Standards Code do not apply to this edition without appropriate adoption and the required filing.

This format of this code is common standards applicable to occupancy applications under the authority of Sections of this code which are applicable for each state agency contained in provisions are applicable to a specific

1. Establish the type of occupancy
2. Verify which state agency has a 100 through 102.
3. Once the appropriate agency has
4. The application must file its information regarding each green
5. Each green building measure the number in Chapters 4 through 6.
6. More information is available for sections contained in Chapter 4.

2007 CALIFORNIA GREEN BUILDING STANDARDS CODE

PREFACE

This document is Part 11 of the official compilation and publication of the adoptions, amendments and repeal of regulations to California Code of Regulations, Title 24, also referred to as the California Building Standards Code. This Part is known as the California Green Building Standards Code.



California PUC's Application of AB32 to Buildings

4 BIG BOLD

Energy Efficiency Strategies



Commercial New Construction

- All new commercial construction in California will be zero net energy by 2030.



Residential New Construction

- All new residential construction in California will be zero net energy by 2020.






Residential / Small Commercial HVAC

- Heating, Ventilation, and Air Conditioning (HVAC) industry will be reshaped



Low-Income Energy Efficiency

- All eligible low-income homes will be energy-efficient by 2020



Grueneich, 2008



July 2008

California **long term ENERGY EFFICIENCY STRATEGIC PLAN**

ACHIEVING **MAXIMUM ENERGY SAVINGS** IN CALIFORNIA FOR 2009 AND BEYOND

RESEARCH & TECHNOLOGY

COMMERCIAL SECTOR

MARKETING, EDUCATION & OUTREACH

INDUSTRIAL SECTOR


WORKFORCE EDUCATION & TRAINING

STANDARDS

LOCAL GOVERNMENTS

RESIDENTIAL SECTOR INCLUDING LOW INCOME

DSM COORDINATION AND INTEGRATION

California Public Utilities Commission 

Energy and Environmental Economics, Inc. Report to the California Energy Commission PIER

Developing a Greenhouse Gas Tool for Buildings in California: Methodology and Use

September 10, 2008

Prepared by:

Amber Mahone, Snuller Price, William Morrow
Energy and Environmental Economics, Inc.
101 Montgomery, Suite 1600
San Francisco, California, 94104
Phone: 415-391-5100
Fax: 415-391-6500
Web: <http://www.eeae.com>

 Energy and Environmental Economics, Inc.



What's Happening from **Environmental Building News**
October 1, 2008



DISCUSSIONS

There are no comments for this page yet.

[Log in to add comments](#)

NEWS

- *Environmental Building News* (October 2008)
- Features
- What's Happening
- Product News & Reviews
- BackPage Primers
- Opinion
- GreenSource Magazine
- *EBN* Archives

Energy-Use Reporting Mandated in California

A law requiring annual energy-use reporting for all California's nonresidential buildings takes effect in January 2009, and the state Department of General Services has been working closely with utilities to streamline the reporting process. Beginning in 2010 owners of commercial buildings must disclose their energy usage and Energy Star rating to potential buyers, leasers, and financiers. The legislation, which is similar to a European Union (EU) requirement that took effect in 2006-7, was signed into law in October 2007.

While this law does not directly require public disclosure of the energy performance of individual buildings, as mandated by Washington, D.C.'s new Clean and Affordable Energy Act (see *EBN* Vol. 17, No. 9), real-estate listing services are likely to include it. "My expectation is that for most buildings it will actually be made public," reported Douglas Mahone, principal of the consulting firm Heschong Mahone Group.

RELATED ARTICLES

Regulations Demanding Actual Data Are Leapfrogging LEED
EBN: From the Editors - October 2008

[▶ More related articles](#)

RELATED GREEN DESIGN



Target Finder

*** REQUIRED**

Select a target rating and/or compare your Design Energy to the target.

1. Facility Information

*Zip Code Facility Name
City State

2. Facility Characteristics

*Select Space Type(s) for this project.

[Space Types]

Office

Delete

*Gross Floor Area	*Operating Hours/Week	*Workers on Main Shift	*Number of PCs	*Office Air-Conditioned	*Office Heated
<input type="text" value="21000"/> Sq. Ft.	<input type="text" value="50"/> Hours	<input type="text" value="50"/>	<input type="text" value="50"/>	<input type="text" value="50% or more"/>	<input type="text" value="50% or more"/>

3. The Target¹

[Target Rating](#)

[Energy Reduction Target](#)

Select

Or

*Choose the design target and select "View Results" to display associated energy use for the target.



TARGET FINDER



PRINT



FREQUENTLY ASKED QUESTIONS



CONTACT US



HELP

[Return to ENERGY STAR Web site](#) > [Target Energy Performance Results](#)

Target Energy Performance Results

The design **must** achieve a rating of 75 or higher to be eligible for "Designed to Earn the ENERGY STAR". **View Statement of Energy Design Intent** for project summary.

[View](#)

NOTE: Assumptions are 82% electricity and 18% % Natural Gas. The Target & Top 10% energy use for this facility are calculated based on the typical fuel mix in the zip code specified.

Target Energy Performance Results (estimated)			
Energy	Design	Target	Top 10%
Energy Performance Rating (1-100)	N/A	93	90
Energy Reduction (%)	N/A	50	45
Source Energy Use Intensity (kBtu/Sq. Ft./yr)	N/A	97.9	107.5
Site Energy Use Intensity (kBtu/Sq. Ft./yr)	N/A	33.4	36.6
Total Annual Source Energy (kBtu)	N/A	2,055,078.9	2,256,625.5
Total Annual Site Energy (kBtu)	N/A	700,402.7	769,092.9
Total Annual Energy Cost (\$)	N/A	\$ 22,605	\$ 24,822
Pollution Emissions			
CO2-eq Emissions (metric tons/year)	N/A	90.7	99.6
CO2-eq Emissions Reduction (%)	N/A	50%	45%



Building Carbon Performance Standard (BCPS) - 2008

ASHRAE Climate Zones	Small Office	Medium Office	Large Office	Primary School	Secondary School	Hospital (Acute Care or Children's)	Hotel (Economy & Budget)	Hotel (Midscale w/ Food & Beverage)	Hotel (Upscale)	Medical Office	Residence Hall / Dormitory	Supermarket / Grocery	Warehouse (Unrefrigerated)	Courthouse	Bank / Financial Institution	Retail	Strip Mall
1A	13.57	15.97	21.26	8.16	8.61	31.59	13.76	10.95	14.70	14.46	10.25	56.61	4.86	16.93	16.93	17.30	20.80
2A	12.75	15.12	20.35	7.86	8.29	31.50	13.42	10.75	14.33	13.26	10.10	49.50	4.86	16.09	16.09	16.84	20.35
2B	13.33	15.71	20.94	8.27	8.73	30.77	14.26	11.29	15.05	14.10	10.76	53.36	5.24	16.66	16.66	17.44	20.94
3A	12.53	14.92	20.15	7.87	8.27	31.15	13.84	11.01	14.60	12.85	10.34	46.45	5.05	15.88	15.88	16.97	20.45
3B-CA	10.60	13.01	18.25	6.68	7.05	33.30	9.93	8.55	11.55	10.53	8.62	34.11	3.94	13.94	13.94	14.95	18.42
3B-other	13.91	16.31	21.55	8.66	9.13	30.06	15.13	11.80	15.74	15.00	11.33	57.19	5.69	17.26	17.26	18.07	21.55
3C	10.94	13.31	18.52	7.09	7.46	31.71	12.06	9.91	13.15	10.90	9.47	34.86	4.58	14.26	14.26	15.64	19.12
4A	12.85	15.21	20.42	8.28	8.72	29.59	15.23	11.88	15.66	13.23	11.57	46.27	6.08	16.15	16.15	17.78	21.23
4B	12.65	15.04	20.24	8.14	8.56	30.03	14.83	14.79	15.24	12.99	11.19	45.28	5.77	15.98	15.98	17.46	20.95
4C	12.02	14.28	19.66	7.89	8.33	29.94	14.58	11.49	15.03	12.12	11.21	39.45	5.65	15.35	15.35	17.19	20.49
5A	13.20	15.57	20.70	8.62	9.08	28.17	16.29	12.51	16.20	13.70	12.77	47.13	7.33	16.49	16.49	18.47	21.90
5B	13.14	15.48	20.65	8.71	9.07	28.64	16.44	12.65	16.40	13.62	12.71	46.20	7.05	16.42	16.42	18.46	21.88

Units: Carbon Use Intensity (CUI) lbs-CO2/ft2-yr



Energy Certificate

Building Energy Performance >		As built:
Certificate type	FULL	Asset Rating
Building Type	Office	
Whole or part of building	Whole building	
<i>Very energy efficient</i>		B
A		
B		
D		
E		
F		
G		
<i>Not energy efficient</i>		Calculated
Asset rating method:	UK National Standard 2004	
Operational rating method:	UK Office Tailored Benchmarks 2002	
Units used:	kg CO ₂ per sq m of net area per annum >	
Occupancy level:	Square metres net lettable area per person	
Equipment heat gain level:	Watts per square metre net	
Weekly occupancy hours:	Hours per week	
Heating performance ratings:	A B C D E F G	
HVAC performance ratings (cooling, fans and pumps):	A B C D E F G	
Lighting performance ratings:	A B C D E F G	
Management rating (for in-use performance only):		
Internal Environmental Quality		
Risk level:		
Further information can be found in the Energy Log Book		

GB 2007



ASU's Current Campus Energy Information System



Energy Information System Building Monitoring

- Campus Overview
- Monitoring
- Alarm Profile
- User Profile
- General Reports
- Administration



POWERED BY
APS energy SERVICES

Temp : 80 °F / 26 °C
Humidity : 19.01

Typical Campus Building Profile

- Monitoring
- Alarm Profile
- User Profile
- General Reports
- Administration

Utility: Electricity
Utility Type: kW
View

Hayden Lib

— Value — ForecastedValue — CurMonthPeak — LastMonthPeak

Data Point	Reading
kW	223.56
kWh	223.56
Electric BTU	762,796.90
CHW BTU	1,180.00
CHWS Temp	44.70
CHWR Temp	62.06
CHW Delta T	17.36

kWh, CHTBTU, HTBTU, STBTU are calculated

Refresh every minute

Time Stamp	Actual	Forecasted	Current Month Peak	Last Month Peak
17:50	223.56	233.84	0.00	0.00





GIOS BUILDING:
Resource Usage

All Usage	Heating	Cooling	Electricity	Renewable Resources	Total Resources
-----------	---------	---------	-------------	---------------------	-----------------

Current



Building Floor Area: 44,450 sq ft.
Occupancy: 242
Use: Office

Heating



0
mmBTU/hr
(Million British Thermal Unit)



Cooling



0
TON
(Cooling Ton)



Electricity



21.1
kW
(Kilowatt)



Renewable Resources



Coming Soon
kW
(Kilowatt)





GIOS BUILDING:
Resource Usage

All Usage

Heating

Cooling

Electricity

Renewable Resources

Total Resources

Current

Today

This Week

This Month



Building Floor Area: 44,450 sq ft.
Occupancy: 242
Use: Office



Home

Campus Map

Select Building ▾

Additional Info.

Thursday 10/23/2008 3:00 PM

Temp 86.6° Humidity 4.2%

Building Comparison

Select a structure type: ▾

Download Data


Electricity

Heating

Cooling

Total

Current | Today | This Week | This Month | This Year | % Change



<http://cm.asu.edu>



Conclusion

The next generation of codes will be performance oriented.

The entire environmental impact of a building will need to be considered, will moved from a point based system to a life-cycle based system.

New tools will be available for benchmarking and measuring performance.

Reporting of performance will be mandated and transparent.

In a carbon cap & trade world, not meeting performance will result in economic penalties.



Thank You

For more Information Contact:
harvey.bryan@asu.edu